

State / Regional / District / Public Health Laboratory, Pune

E- mail – ID :- Statehealthlab @ gmail. Com Phone No : 020- 26330225

REPORT ON CHEMICAL EXAMINATION OF P - BLOCK & S - BLOCK FILTER WATER.

Date of Collection :- - Date of Receipt :- 10 / 12 / 2020 Date of Examination :- 12 / 12 / 2020

( All the Analytical Results are in mg / Litre except pH, Turbidity )

Sr. No.	TEST PARAMETER	S.NO. ( 1 )	S.NO. ( 2 )	BIS Specification 10500 : 2012 Normal Values	
		P - Block	S - Block	Desirable Limits	Permissible Limits
1	Physical Appearance	Clear	Clear	---	---
2	Odour	Agreeable	Agreeable	Agreeable	Agreeable
3	Turbidity ( as N.T.U. )	0.10	0.08	1.0	5.0
4	pH Value	7.22	7.38	6.5 to 8.5	No relaxation
5	Chlorides ( as Cl )	2.82	6.57	250	1000
6	Nitrates ( as No <sub>3</sub> )	0.779	0.593	45	No relaxation
7	Total Hardness ( as CaCO <sub>3</sub> )	1.0	1.0	200	600
8	Alkalinity ( as CaCO <sub>3</sub> )	4.8	9.6	200	600
9	Total Dissolved Solids	14.83	28.26	500	2000
10	Iron ( as Fe )	ND	ND	1.0	No relaxation
11	Fluoride ( as F )	0.1223	0.3397	1.0	1.5

- N.D. :- Not Detected.
- This report is restricted only for the Sample/s is Submitted to this Laboratory.
- This Sample/s is / are not Collected by this Laboratory.

S. No. - 1 & 2 are Chemically fit for drinking purpose on the basis of analysed parameters only.  
This water source can be used for drinking purpose only after proper treatment, disinfection and ascertaining its bacteriological quality frequently or regularly.

HEALTH SERVICES

No. / SPHL / D - 79 / 859 / 2020

Date :- 5/11/21

For warded With compliments To :- PICT Model School,  
Mahalunge.

With reference to letter No. -----


Dated :- 10/12/2020


Fees Rs :- 1200 /-

Receipt No. & Date :- 0707386

10/12/2020

  
Principal  
PICT Model School  
Sr. No. 6, Mhalunge-Balewadi,  
Pune - 411 045.

  
Manager  
PICT Model School  
Sr. No. 6, Mhalunge-Balewadi,  
Pune - 411 045.

  
( Prasad Gaikwad )  
Government Analyst  
State Public Health Laboratory, Pune.

REPORT ON CHEMICAL EXAMINATION OF BORE - FILTER WATER

Date of Collection :- ---- Date of Receipt :- 10/02/2021 Date of Examination :- 12/02/2021

( All the Analytical Results are in mg / Litre except pH, Turbidity )

Sr. No.	TEST PARAMETER	S.NO. ( 1 )	S.NO. ( 2 )	BIS Specification 10500 : 2012 Normal Values	
		BORE FILTER WATER	BORE FILTER WATER	Desirable Limits	Permissible Limits
1	Physical Appearance	Clear	Clear	---	---
2	Odour	Agreeable	Agreeable	Agreeable	Agreeable
3	Turbidity ( as N.T.U. )	0.21	0.26	1.0	5.0
4	pH Value	7.24	7.02	6.5 to 8.5	No relaxation
5	Chlorides ( as Cl )	9.78	9.78	250	1000
6	Nitrates ( as No <sub>3</sub> )	6.533	9.753	45	No relaxation
7	Total Hardness ( as CaCO <sub>3</sub> )	2.00	17.00	200	600
8	Alkalinity ( as CaCO <sub>3</sub> )	12.15	24.31	200	600
9	Total Dissolved Solids	36.86	56.5	500	2000
10	Iron ( as Fe )	0.24	ND	1.0	No relaxation
11	Fluoride ( as F )	ND	ND	1.0	1.5

- ND :- Not detected.
- This report is restricted only for the Sample/s is Submitted to this Laboratory.
- This Sample/s is / are not Collected by this Laboratory.

S. No. – 1&2 are Chemically fit for drinking purpose on the basis of analysed parameters only.

This water source can be used for drinking purpose only after proper treatment, disinfection and ascertaining its bacteriological quality frequently or regularly.

HEALTH SERVICES

No. / SPHL / D – 79 / 155 / 2021

Date :- 25/2/21

For warded With compliments To :- PICT MODEL SCHOOL, MAHALUNGE.


With reference to letter No. -----

Dated :- 10/02/2021


Fees Rs :- 1200 /-

Receipt No.& Date:- 0707696

10-02-2021

  
Principal  
PICT Model School  
Sr. No. 6, Mhalunge-Balewadi,  
Pune - 411 045.

  
Manager  
PICT Model School  
Sr. No. 6, Mhalunge-Balewadi,  
Pune - 411 045.

  
( Prasad Gaikwad )  
Government Analyst,  
State Public Health Laboratory, Pune.

State / Regional / District / Public Health Laboratory, Pune  
 E- mail – ID : - Statehealthlab @ gmail. Com Phone No : 020- 2633022  
**REPORT ON CHEMICAL EXAMINATION OF P & S BLOCK WATER**

Date of Collection : - ---- Date of Receipt : - 13/ 01 / 2021 Date of Examination :- 15/ 01/ 2021

( All the Analytical Results are in mg / Litre except pH, Turbidity )

Sr. No.	TEST PARAMETER	S.NO.(1) P- Block	S.NO.(2) S - Block	BIS Specification 10500 : 2012 Normal Values	
				Desirable Limits	Permissible Limits
1	Physical Appearance	Clear	Clear	---	---
2	Odour	Aggreable	Aggreble	Agreeable	Agreeable
3	Turbidity ( as N.T.U. )	0.42	0.38	1.0	5.0
4	pH Value	7.32	7.34	6.5 to 8.5	No relaxation
5	Chlorides ( as Cl )	9.39	9.39	250	1000
6	Nitrates ( as NO <sub>3</sub> )	2.2734	3.6879	45	No relaxation
7	Total Hardness ( as CaCO <sub>3</sub> )	1.80	1.80	200	600
8	Alkalinity ( as CaCO <sub>3</sub> )	15.40	17.32	200	600
9	Total Dissolved Solids	38.68	39.70	500	2000
10	Iron ( as Fe )	ND	ND	1.0	No relaxation
11	Fluoride ( as F )	0.5800	0.5593	1.0	1.5

- N.D.-: Not Detected.
- This report is restricted only for the Sample/s is Submitted to this Laboratory
- This Sample/s is / are not Collected by this Laboratory.

Sample No. – 1&2 are Chemically fit for drinking purpose on the basis of analysed parameters only.

This water source can be used for drinking purpose only after proper treatment, disinfection and ascertaining its bacteriological quality frequently or regularly

HEALTH SERVICES

No. / SPHL / D - 79 / 924 / 2021

Date :- 27/1/21

For warded With compliments To :- PICT Model School , Mhalunge.


With reference to letter No. ----- Dated :- 13/ 01/2021

Fees Rs :1200/- -

Receipt No:- 0707559  
13/01/2021

  
**Manager**  
 PICT Model School  
 Sr. No. 6, Mhalunge-Balewadi,  
 Pune - 411 045.

  
**Principal**  
 PICT Model School  
 Sr. No. 6, Mhalunge-Balewadi,  
 Pune - 411 045.

  
 ( Prasad Gaikwad )  
**Government Analyst,**  
 State Public Health Laboratory,Pune.

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION**

**CERTIFICATE**

Date:- 19 /01/2021

**PICT MODEL SCHOOL  
Sr. No.6, Beside Balewadi Stadium,  
Mhalunge, Pune-411045**

It is certified that an inspection team headed by Dr. SANTOSH R. MULE form PMC Health Department inspected the school premises, PICT MODEL SCHOOL, Sr.No.-6, Behind Ramada Plaza Hotel, Near Balewadi Stadium, Mhalunge-Balewadi, Pune-411045 on 19/01/2021 and found that the PICT MODEL SCHOOL, Sr.No.-6, Behind Ramada Plaza Hotel, Near Balewadi Stadium, Mhalunge-Balewadi, Pune-411045 has safe drinking water facilities for the Students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above is valid for valid for a period of 18 /01/2022

18/1/2022




Zone Commissioner

Office Zone No-2

In ward No:- \_\_\_\_\_

Date:- /01/2021



Signature with Seal:- 

Name:-

**DR. Santosh Mule**  
**20th Health Officer**  
**PMC.**

Designation:-

क्षेत्रिय आयुक्त (परिमंडल क्र.२) कार्यालय

पुणे महानगरपालिका

जावक क्र. क्षेआप२/४६३२दि. १९/१/२०२१